



- ① VERTICAL REINFORCING
- ② HORIZONTAL REINFORCING
- ③ 3" DEEP BOND BEAM WITH (1) #4 CONTINUOUS BAR
- ④ 2X NAILER PLATE WITH 1/2" DIAMETER ANCHOR BOLTS AT 48" O.C.
- ⑤ 2X SOLID BLOCKING BETWEEN TRUSSES WITH 16d AT 6" O.C. FASTENED TO WALL TOP NAILER
- ⑥ H2.5 CLIP TO EACH ROOF TRUSS. FASTENED DIRECTLY TO TOP NAILER
- ⑦ STRUCTURAL SHEATHING
- ⑧ FOAM EPS WITH LATH OVERLAPING ICF MIN. 12"
- ⑨ 2 X 8 WD. PLATE

NOTE:

ICF SCREEN GRID TO BE PER IRC 2012
FOOTING WIDTH, REBAR SIZE AND
SPACING
PER SECTION R611 - 2012

01 ROOF TRUSS WITH PARAPET AT ICF WALL

SCALE: 1'-0" = 3/4"